

Chemicals and Parameters in California Drinking Water Quality Database
December 19, 2007

STORET No. = US EPA STORET number for chemical (A-XXX indicates the ID was assigned by CDPH in the absence of a STORET number)

MCL = Maximum Contaminant Level

DLR = Detection limit for purposes of reporting

Reporting units: ug/L = micrograms per liter; mg/L = milligrams per liter; pCi/l = picocuries per liter; MFL - million fibers per liter

NOTE: This list is intended to be used as a quick reference.

Refer to the chemical list and STORET numbers in Write-On for data submittal. [see <http://www.cdph.ca.gov/certlic/drinkingwater/Pages/EDTlibrary.a>]

Chemical / Parameter	STORET No.	MCL	DLR	Units
ACENAPHTHENE	34205	n/a	5	ug/L
ACENAPHTHYLENE	34200	n/a	5	ug/L
ACEPHATE	81815	n/a	10	ug/L
ACETALDEHYDE	77001	n/a	--	ug/L
ACETAMINOPHEN	A-058	n/a	--	ug/L
ACETOCHLOR	04240	n/a	--	ug/L
ACETOCHLOR ETHANE SULFONIC ACID (ESA)	A-089	n/a	--	ug/L
ACETOCHLOR OXANILIC ACID (OA)	A-090	n/a	--	ug/L
ACETONE	81552	n/a	--	ug/L
ACIFLURFEN	79193	n/a	--	ug/L
ACRITET	34216	n/a	--	ug/L
ACROLEIN	34210	n/a	--	ug/L
ACRYLONITRILE (ACRITET)	34216	n/a	--	ug/L
ACTI-DIONE	A-002	n/a	--	ug/L
AGGRESSIVE INDEX (CORROSIVITY)	82383	n/a	--	
ALACHLOR	77825	2	1	ug/L
ALACHLOR ETHANE SULFONIC ACID (ESA)	A-094	n/a	--	ug/L
ALACHLOR OXANILIC ACID (OA)	A-091	n/a	--	ug/L
ALDICARB	39053	n/a	3	ug/L
ALDICARB SULFONE	A-020	n/a	4	ug/L
ALDICARB SULFOXIDE	A-019	n/a	3	ug/L
ALDRIN	39330	n/a	0.075	ug/L
ALICEP	45608	n/a	--	ug/L
ALKALINITY (TOTAL) AS CaCO3	00410	n/a	--	mg/L
C3-ALKYLBENZENE	45046	n/a	--	ug/L
C4-ALKYLBENZENE	45049	n/a	--	ug/L
ALUMINUM	01105	1000	50	ug/L
AMETRYN	82184	n/a	--	ug/L
AMIBEN	82051	n/a	--	ug/L
AMINOCARB	38404	n/a	--	ug/L
AMINOTRIAZOLE	73509	n/a	--	ug/L
AMMONIA (NH3-N)	00612	n/a	--	mg/L
AMOXICILLIN	A-059	n/a	--	ug/L
ANTHRACENE	34220	n/a	5	ug/L
ANTIMONY	01097	6	6	ug/L
ARSENIC	01002	10	2	ug/L
ASBESTOS	81855	7	0.2	MFL
ATRATON	82185	n/a	--	ug/L
ATRAZINE	39033	1	0.5	ug/L
AZINPHOS ETHYL	81292	n/a	--	ug/L
AZITHROMYCIN	A-060	n/a	--	ug/L
BARBAN	38418	n/a	--	ug/L
BARIUM	01007	1000	100	ug/L
BENFLURALIN	39002	n/a	--	ug/L
BENOMYL	38705	n/a	100	ug/L
BENTAZON	38710	18	2	ug/L
BENZENE	34030	1	0.5	ug/L
BENZIDINE	39120	n/a	5	ug/L
BENZO (A) ANTHRACENE	34526	n/a	10	ug/L
BENZO (A) PYRENE	34247	0.2	0.1	ug/L
BENZO (B) FLUORANTHENE	34230	n/a	10	ug/L
BENZO (GHI) PERYLENE	34521	n/a	10	ug/L

Chemicals and Parameters in California Drinking Water Quality Database
December 19, 2007

STORET No. = US EPA STORET number for chemical (A-XXX indicates the ID was assigned by CDPH in the absence of a STORET number)

MCL = Maximum Contaminant Level

DLR = Detection limit for purposes of reporting

Reporting units: ug/L = micrograms per liter; mg/L = milligrams per liter; pCi/l = picocuries per liter; MFL - million fibers per liter

NOTE: This list is intended to be used as a quick reference.

Refer to the chemical list and STORET numbers in Write-On for data submittal. [see <http://www.cdph.ca.gov/certlic/drinkingwater/Pages/EDTlibrary.a>]

Chemical / Parameter	STORET No.	MCL	DLR	Units
BENZO (K) FLUORANTHENE	34242	n/a	10	ug/L
BENZYL BUTYL PHTHALATE	34292	n/a	10	ug/L
BERYLLIUM	01012	4	1	ug/L
BETASAN	82197	n/a	--	ug/L
BHC, alpha	39337	n/a	0.01	ug/L
BHC, beta	39338	n/a	0.05	ug/L
BHC, delta	34259	n/a	0.05	ug/L
BICARBONATE ALKALINITY	00440	n/a	--	mg/L
BIS (2-CHLOROEOXY) METHANE	34278	n/a	5	ug/L
BIS (2-CHLOROETHYL) ETHER	34273	n/a	--	ug/L
BIS (2-CHLOROISOPROPYL) ETHER	34283	n/a	5	ug/L
BIS 1,1-DIMETHYLETHYLPEROXIDE	A-018	n/a	--	ug/L
BIS 1,1-DIMETHYLPEROXIDE	A-015	n/a	--	ug/L
BISPHENOL A	81651	n/a	--	ug/L
BORON	01020	n/a	100	ug/L
BROMACIL	82198	n/a	10	ug/L
BROMATE	A-027	10	5.0	ug/L
BROMIDE	82298	n/a	--	mg/L
BROMOBENZENE	81555	n/a	0.5	ug/L
BROMOCHLOROACETIC ACID (BCAA)	A-038	n/a	1	ug/L
BROMOCHLOROMETHANE	A-012	n/a	0.5	ug/L
BROMODICHLOROMETHANE (THM)	32101	--	1.0	ug/L
BROMODICHLOROACETIC ACID (BDCAA)	A-039	n/a	1	ug/L
BROMOFORM (THM)	32104	--	1.0	ug/L
4-BROMOPHENYL PHENYL ETHER	34636	n/a	5	ug/L
BROMOMETHANE	34413	n/a	0.5	ug/L
BUTACHLOR	77860	n/a	0.38	ug/L
BUTYLATE	81410	n/a	--	ug/L
N-BUTYLBENZENE	A-010	n/a	0.5	ug/L
sec-BUTYLBENZENE	77350	n/a	0.5	ug/L
tert-BUTYLBENZENE	77353	n/a	0.5	ug/L
CADMIUM	01027	5	1	ug/L
CALCIUM	00916	n/a	--	mg/L
CAFFEINE	81436	n/a	--	ug/L
CAPTAN	39640	n/a	0.1	ug/L
CAPTATOL	39031	n/a	--	ug/L
CARBAMAZEPINE	A-061	n/a	--	ug/L
CARBARYL	77700	n/a	5	ug/L
CARBENDAZIM	38735	n/a	--	ug/L
CARBOFURAN	81405	18	5	ug/L
CARBON DIOXIDE	77000	n/a	--	ug/L
CARBON DISULFIDE	77041	n/a	0.5	ug/L
CARBON TETRACHLORIDE	32102	0.5	0.5	ug/L
CARBONATE ALKALINITY	00445	n/a	--	mg/L
CARBOPHENOTHION	39786	n/a	--	ug/L
CASORON	82297	n/a	--	ug/L
CHLORATE	A-037	n/a	20	ug/L
CHLORDANE	39350	0.1	0.1	ug/L
CHLORDECONE	81281	n/a	--	ug/L
CHLORDIMEFORM	77953	n/a	--	ug/L
CHLORIDE	00940	600	--	mg/L
CHLORINE DIOXIDE	50070	n/a	--	mg/L

Chemicals and Parameters in California Drinking Water Quality Database
December 19, 2007

STORET No. = US EPA STORET number for chemical (A-XXX indicates the ID was assigned by CDPH in the absence of a STORET number)

MCL = Maximum Contaminant Level

DLR = Detection limit for purposes of reporting

Reporting units: ug/L = micrograms per liter; mg/L = milligrams per liter; pCi/l = picocuries per liter; MFL - million fibers per liter

NOTE: This list is intended to be used as a quick reference.

Refer to the chemical list and STORET numbers in Write-On for data submittal. [see <http://www.cdph.ca.gov/certlic/drinkingwater/Pages/EDTlibrary.a>]

Chemical / Parameter	STORET No.	MCL	DLR	Units
CHLORITE	50074	1	0.020	mg/L
CHLOROBENZILATE	39460	n/a	--	ug/L
CHLOROETHANE	34311	n/a	0.5	ug/L
2-CHLOROETHYLVINYL ETHER	34576	n/a	--	ug/L
CHLOROFORM (THM)	32106	--	1.0	ug/L
CHLOROMETHANE	34418	n/a	0.5	ug/L
4-CHLORO-3-METHYLPHENOL	34452	n/a	5	ug/L
2-CHLORONAPHTHALENE	34581	n/a	5	ug/L
CHLORONEB	38423	n/a	0	ug/L
2-CHLOROPHENOL	34586	n/a	5	ug/L
4-CHLOROPHENYL PHENYL ETHER	34641	n/a	5	ug/L
CHLOROPICRIN	77548	n/a	1	ug/L
CHLOROPROPHAM	81322	n/a	--	ug/L
CHLOROPROPYLATE	38429	n/a	--	ug/L
CHLOROTHALONIL	70314	n/a	5	ug/L
2-CHLOROTOLUENE	A-008	n/a	0.5	ug/L
4-CHLOROTOLUENE	A-009	n/a	0.5	ug/L
CHLOROTOLUENE	77970	n/a	--	ug/L
CHLORPYRIFOS	77969	n/a	1	ug/L
CHLORSULFURON	A-006	n/a	--	ug/L
CHLORTHAL	39770	n/a	0.1	ug/L
CHROMIUM (TOTAL)	01034	50	10	ug/L
CHROMIUM (TOTAL) - HEX CHROME SCREENING ONLY	retired	--	1	ug/L
CHROMIUM, HEXAVALENT	01032	n/a	1	ug/L
CHRYSENE	34320	n/a	5	ug/L
CIODRIN	82565	n/a	--	ug/L
CIPROFLOXACIN	A-062	n/a	--	ug/L
COBALT	01035	n/a	--	ug/L
COLOR	00081	15	--	UNITS
COPPER	01042	1000	50	ug/L
COUMAPHOS	81293	n/a	--	ug/L
CRESOTE	39140	n/a	--	ug/L
CUMENE (ISOPROPYLBENZENE)	77223	n/a	0.5	ug/L
CYANAZINE	81757	n/a	150	ug/L
CYANIDE	01291	150	100	ug/L
CYCLOATE	81892	n/a	--	ug/L
2,4-D	39730	70	10	ug/L
DALAPON	38432	200	10	ug/L
2,4-DB	38746	n/a	0	ug/L
DCPA (TOTAL DI & MONO ACID DEGRADATES)	A-045	n/a	--	ug/L
D-D MIXTURE	A-013	n/a	--	ug/L
4,4-DDD	39310	n/a	0.02	ug/L
DDD	39360	n/a	--	ug/L
4,4-DDE	39320	n/a	0.01	ug/L
DDE	39365	n/a	--	ug/L
4,4-DDT	39300	n/a	0.02	ug/L
DDT	39370	n/a	--	ug/L
DDVP	38775	n/a	--	ug/L
DEMETON	39560	n/a	--	ug/L
DIAZINON	39570	n/a	--	ug/L
DIBENZO (A,H) ANTRACENE	34556	n/a	5	ug/L
DIBROMOACETIC ACID (DBAA) (one of the HAA5)	82721	--	1.0	ug/L

Chemicals and Parameters in California Drinking Water Quality Database
December 19, 2007

STORET No. = US EPA STORET number for chemical (A-XXX indicates the ID was assigned by CDPH in the absence of a STORET number)

MCL = Maximum Contaminant Level

DLR = Detection limit for purposes of reporting

Reporting units: ug/L = micrograms per liter; mg/L = milligrams per liter; pCi/l = picocuries per liter; MFL - million fibers per liter

NOTE: This list is intended to be used as a quick reference.

Refer to the chemical list and STORET numbers in Write-On for data submittal. [see <http://www.cdph.ca.gov/certlic/drinkingwater/Pages/EDTlibrary.a>]

Chemical / Parameter	STORET No.	MCL	DLR	Units
DIBROMOCHLOROACETIC ACID (DBCAA)	A-040	n/a	2	ug/L
DIBROMOCHLOROMETHANE (THM)	32105	--	1.0	ug/L
DIBROMOCHLOROPROPANE (DBCP)	38761	0.2	0.01	ug/L
DIBROMOMETHANE	77596	n/a	0.5	ug/L
DI-N-BUTYLPHTHALATE	39110	n/a	5	ug/L
DICAMBA	82052	n/a	1.5	ug/L
DICHLORAN	38447	n/a	0	ug/L
DICHLOROACETIC ACID (DCAA) (one of the HAA5)	77288	--	1.0	ug/L
1,2-DICHLOROBENZENE	34536	600	0.5	ug/L
1,3-DICHLOROBENZENE	34566	n/a	0.5	ug/L
1,4-DICHLOROBENZENE	34571	5	0.5	ug/L
3,3-DICHLOROBENZIDINE	34631	n/a	20	ug/L
DICHLOROBROMOMETHANE	34328	100	0.5	ug/L
1,4-DICHLOROBUTANE	77285	n/a	--	ug/L
DICHLORODIFLUOROMETHANE (FREON 12)	34668	n/a	0.5	ug/L
1,1-DICHLOROETHANE	34496	5	0.5	ug/L
1,2-DICHLOROETHANE	34531	0.5	0.5	ug/L
1,1-DICHLOROETHYLENE	34501	6	0.5	ug/L
cis-1,2-DICHLOROETHYLENE	77093	6	0.5	ug/L
trans-1,2-DICHLOROETHYLENE	34546	10	0.5	ug/L
DICHLOROMETHANE	34423	5	0.5	ug/L
2,4-DICHLOROPHENOL	34601	n/a	5	ug/L
1,1-DICHLOROPROPANE	A-007	n/a	--	ug/L
1,2-DICHLOROPROPANE	34541	5	0.5	ug/L
1,3-DICHLOROPROPANE	77173	n/a	0.5	ug/L
2,2-DICHLOROPROPANE	77170	n/a	0.5	ug/L
DICHLOROPROPANE	81327	n/a	--	ug/L
1,1-DICHLOROPROPENE	77168	n/a	0.5	ug/L
cis-1,3-DICHLOROPROPENE	34704	0.5	0.5	ug/L
trans-1,3-DICHLOROPROPENE	34699	0.5	0.5	ug/L
1,3-DICHLOROPROPENE (TOTAL)	34561	0.5	0.5	ug/L
DICHLORPROP	82356	n/a	--	ug/L
DICOFOL	39780	n/a	0.1	ug/L
DICROTOPHOS	38454	n/a	--	ug/L
DIELDRIN	39380	n/a	0.02	ug/L
DIETHYLBENZENE	78214	n/a	--	ug/L
DI(2-ETHYLHEXYL)ADIPATE	A-026	400	5	ug/L
DI(2-ETHYLHEXYL)PHTHALATE	39100	4	3	ug/L
DIETHYL PHTHALATE	34336	n/a	5	ug/L
DIFENZOQUAT	78882	n/a	--	ug/L
DIISOPROPYL ETHER	A-036	n/a	--	ug/L
DIMETHOATE	38458	n/a	--	ug/L
DIMETHYL PHTHALATE	34341	n/a	5	ug/L
2,4-DIMETHYLPHENOL	34606	n/a	5	ug/L
1,3-DINITROBEZENE	A-083	n/a	--	ug/L
4,6-DINITRO-o-CRESOL	A-050	n/a	--	ug/L
2,4-DINITROPHENOL	34616	n/a	5	ug/L
2,4-DINITROTOLUENE	34611	n/a	5	ug/L
2,6-DINITROTOLUENE	34626	n/a	5	ug/L
DINOSEB	81287	7	2	ug/L
DI-N-OCTYLPHTHALATE	34596	n/a	5	ug/L
1,4-DIOXANE	A-032	n/a	3	ug/L

Chemicals and Parameters in California Drinking Water Quality Database
December 19, 2007

STORET No. = US EPA STORET number for chemical (A-XXX indicates the ID was assigned by CDPH in the absence of a STORET number)

MCL = Maximum Contaminant Level

DLR = Detection limit for purposes of reporting

Reporting units: ug/L = micrograms per liter; mg/L = milligrams per liter; pCi/l = picocuries per liter; MFL - million fibers per liter

NOTE: This list is intended to be used as a quick reference.

Refer to the chemical list and STORET numbers in Write-On for data submittal. [see <http://www.cdph.ca.gov/certlic/drinkingwater/Pages/EDTlibrary.a>]

Chemical / Parameter	STORET No.	MCL	DLR	Units
DIOXATHION	38783	n/a	--	ug/L
DIPHENAMIDE	78004	n/a	100	ug/L
1,2-DIPHENYLHYDRAZINE	34346	n/a	--	ug/L
DIQUAT	78885	20	4	ug/L
DISULFOTON	81888	n/a	100	ug/L
DIURON	39650	n/a	--	ug/L
DNOC	39920	n/a	--	ug/L
DYFONATE	81294	n/a	--	ug/L
DYLOX	39014	n/a	--	ug/L
ENDOSULFAN I	34361	n/a	0.02	ug/L
ENDOSULFAN II	34356	n/a	0.01	ug/L
ENDOSULFAN SULFATE	34351	n/a	0.05	ug/L
ENDOTHALL	38926	100	45	ug/L
ENDRIN	39390	2	0.1	ug/L
ENDRIN ALDEHYDE	34366	n/a	0.05	ug/L
EPN	81290	n/a	--	ug/L
EPTC	81894	n/a	--	ug/L
17-B ESTRADIOL	A-052	n/a	--	ug/L
ESTRONE	A-053	n/a	--	ug/L
ETHANOL	77004	n/a	--	ug/L
ETHINYL ESTRADIOL	A-051	n/a	--	ug/L
ETHION	39398	n/a	--	ug/L
ETHYL PARATHION	46315	n/a	--	ug/L
ETHYL-TERT-BUTYL ETHER	A-033	n/a	3	ug/L
ETHYLBENZENE	34371	300	0.5	ug/L
ETHYLENE DIBROMIDE (EDB)	77651	0.05	0.02	ug/L
ETHYLENE GLYCOL	77023	n/a	--	ug/L
ETHYLENEDIAMINE TETRA-ACETIC ACID (EDTA)	78151	n/a	--	ug/L
ETHYLENE THIO UREA	38928	n/a	5	ug/L
FENAMIPHOS	38929	n/a	5	ug/L
FENSULFOTHION	38797	n/a	--	ug/L
FENTHION	38801	n/a	--	ug/L
FENURON	38468	n/a	--	ug/L
FENURON-TCA	38473	n/a	--	ug/L
FERBAM	38806	n/a	--	ug/L
FLUCHLORALIN	79194	n/a	--	ug/L
FLUOMETURON	38811	n/a	--	ug/L
FLUORANTHENE	34376	n/a	5	ug/L
FLUORENE	34381	n/a	5	ug/L
FLUORIDE -- NATURAL - SOURCE	00951	2	0.1	mg/L
FLUORIDE -- TREATMENT-RELATED - DISTRIBUTION	A-035	see regs	0.1	mg/L
FOAMING AGENTS (MBAS)	38260	0.5	--	mg/L
FONOFOS	04095	n/a	--	ug/L
FORMALDEHYDE	71880	n/a	--	mg/L
GARLON	A-004	n/a	--	ug/L
GEMFIBROZIL	A-063	n/a	--	ug/L
GLYOXAL	A-048	n/a	--	ug/L
GLYPHOSATE	79743	700	25	ug/L
GROSS ALPHA	01501	15	3	pCi/L
GROSS ALPHA COUNTING ERROR	01502	n/a	--	pCi/L
GROSS ALPHA MDA95	A-072	n/a	--	pCi/L
GROSS BETA	03501	n/a	4	pCi/L

Chemicals and Parameters in California Drinking Water Quality Database
December 19, 2007

STORET No. = US EPA STORET number for chemical (A-XXX indicates the ID was assigned by CDPH in the absence of a STORET number)

MCL = Maximum Contaminant Level

DLR = Detection limit for purposes of reporting

Reporting units: ug/L = micrograms per liter; mg/L = milligrams per liter; pCi/l = picocuries per liter; MFL - million fibers per liter

NOTE: This list is intended to be used as a quick reference.

Refer to the chemical list and STORET numbers in Write-On for data submittal. [see <http://www.cdph.ca.gov/certlic/drinkingwater/Pages/EDTlibrary.a>]

Chemical / Parameter	STORET No.	MCL	DLR	Units
GROSS BETA COUNTING ERROR	03502	n/a	--	pCi/L
GROSS BETA MDA95	A-077	n/a	--	pCi/L
GROSS BETA, CALCULATED DOSE EQUIVALENT	A-071	4	--	millirem/ year
GUTHION	39580	n/a	--	ug/L
HAA5 - HALOACETIC ACIDS (FIVE)	A-049	60	--	ug/L
HARDNESS (TOTAL) AS CaCO3	00900	n/a	--	mg/L
HEPTACHLOR	39410	0.01	0.01	ug/L
HEPTACHLOR EPOXIDE	39420	0.01	0.01	ug/L
2,2',4,4',5,5'-HEXABROMOBIPHENYL	A-086	n/a	--	ug/L
2,2',4,4',5,5'-HEXABROMODIPHENYL ETHER	A-087	n/a	--	ug/L
HEXACHLOROBENZENE	39700	1	0.5	ug/L
HEXACHLOROBUTADIENE	34391	n/a	0.5	ug/L
HEXACHLOROCYCLOPENTADIENE	34386	50	1	ug/L
HEXACHLOROETHANE	34396	n/a	5	ug/L
HEXANOL	81591	n/a	--	ug/L
HEXAZINONE	38815	n/a	--	ug/L
HMX	82203	n/a	--	ug/L
HYDRAZINE	81313	n/a	--	ug/L
HYDROGEN SULFIDE	71875	n/a	--	mg/L
HYDROXIDE ALKALINITY	71830	n/a	--	mg/L
3-HYDROXYCARBOFURAN	A-021	n/a	3	ug/L
IBUPROFEN	A-064	n/a	--	ug/L
IMIDAN	39800	n/a	--	ug/L
INDENO (1,2,3-CD) PYRENE	34403	n/a	10	ug/L
IODIDE	71865	n/a	--	mg/L
IODINATED CONTRAST MEDIA	A-065	n/a	--	ug/L
IRON	01045	300	100	ug/L
IRON, DISSOLVED	01046	300	--	ug/L
ISOPHORONE	34408	n/a	10	ug/L
ISOPROPYL ALCOHOL	77015	n/a	--	ug/L
ISOPROPYLBENZENE (CUMENE)	77223	n/a	0.5	ug/L
p-ISOPROPYLTOLUENE	A-011	n/a	--	ug/L
KEROSENE	78878	n/a	--	ug/L
LAMPREYCIDE	01302	n/a	--	ug/L
LANGELIER INDEX @ 60 C	71813	n/a	--	
LANGELIER INDEX AT SOURCE TEMP.	71814	n/a	--	
LEAD	01051	n/a	5	ug/L
LINDANE	39340	0.2	0.2	ug/L
LINURON	38478	n/a	--	ug/L
LIPITOR	A-066	n/a	--	ug/L
LITHIUM	01132	n/a	--	ug/L
LONDAX	A-016	n/a	--	ug/L
MAGNESIUM	00927	n/a	--	mg/L
MALATHION	39530	n/a	--	ug/L
MANCOZEB	38831	n/a	--	ug/L
MANEB	38835	n/a	20	ug/L
MANGANESE	01055	50	20	ug/L
MANGANESE, DISSOLVED	01056	50	--	ug/L
MCPA	39151	n/a	--	ug/L
MCPB	38486	n/a	--	ug/L
MCPB	38492	n/a	--	ug/L
MERCURY	71900	2	1	ug/L

Chemicals and Parameters in California Drinking Water Quality Database
December 19, 2007

STORET No. = US EPA STORET number for chemical (A-XXX indicates the ID was assigned by CDPH in the absence of a STORET number)

MCL = Maximum Contaminant Level

DLR = Detection limit for purposes of reporting

Reporting units: ug/L = micrograms per liter; mg/L = milligrams per liter; pCi/l = picocuries per liter; MFL - million fibers per liter

NOTE: This list is intended to be used as a quick reference.

Refer to the chemical list and STORET numbers in Write-On for data submittal. [see <http://www.cdph.ca.gov/certlic/drinkingwater/Pages/EDTlibrary.a>]

Chemical / Parameter	STORET No.	MCL	DLR	Units
MERPHOS	39019	n/a	--	ug/L
METASYSTOX	39020	n/a	--	ug/L
METHADONE	A-067	n/a	--	ug/L
METHAMIDOPHOS	38927	n/a	10	ug/L
METHIDATHION	78879	n/a	--	ug/L
METHIOCARB	38500	n/a	--	ug/L
METHOMYL	39051	n/a	2	ug/L
METHOXYCHLOR	39480	30	10	ug/L
2-METHYL-4,6-DINITROPHENOL	34657	n/a	5	ug/L
METHYL ETHYL KETONE	81595	n/a	5	ug/L
METHYL ISOBUTYL KETONE	81596	n/a	5	ug/L
METHYL PARATHION	39600	n/a	--	ug/L
2-METHYLPHENOL	A-046	n/a	--	ug/L
METHYL PHENOL	45058	n/a	--	ug/L
METHYL TRITHION	39790	n/a	--	ug/L
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	5	3	ug/L
METOLACHLOR	39356	n/a	--	ug/L
METOLACHLOR ETHANE SULFONIC ACID (ESA)	A-092	n/a	--	ug/L
METOLACHLOR OXANILIC ACID (OA)	A-093	n/a	--	ug/L
METRIBUZIN	81408	n/a	--	ug/L
MEXACARBATE	38507	n/a	--	ug/L
MIREX	39755	n/a	--	ug/L
MODOWN	78883	n/a	--	ug/L
MOLINATE	82199	20	2	ug/L
MOLYDBENDUM	01062	n/a	--	ug/L
MONOBROMOACETIC ACID (MBAA) (one of the HAA5)	A-041	--	1.0	ug/L
MONOCHLOROACETIC ACID (MCAA) (one of the HAA5)	A-042	--	2.0	ug/L
MONOCHLOROBENZENE	34301	70	0.5	ug/L
MONOCROTOPHOS	81890	n/a	--	ug/L
MONURON	38512	n/a	--	ug/L
MONURON-TCA	38517	n/a	--	ug/L
MORPHINE	A-068			
MSMA	38935	n/a	--	ug/L
N-NITROSODIETHYLAMINE (NDEA)	78200	n/a	--	ug/L
N-NITROSODIMETHYLAMINE (NDMA)	34438	n/a	--	ug/L
N-NITROSODI-n-BUTYLAMINE (NDBA)	78207	n/a	--	ug/L
N-NITROSODI-n-PROPYLAMINE (NDPA)	34428	n/a	--	ug/L
N-NITROSODIPHENYLAMINE	34433	n/a	--	ug/L
N-NITROSOMETHYLETHYLAMINE (NMEA)	A-070	n/a	--	ug/L
N-NITROSOPIPERIDINE (NPIP)	73283	n/a	--	ug/L
N-NITROSOPYRROLIDINE (NPYR)	78206	n/a	--	ug/L
N-OCTACOSANE	78116	n/a	--	ug/L
NABAM	38851	n/a	--	ug/L
NALED	38855	n/a	--	ug/L
NAPHTHALENE	34696	n/a	0.5	ug/L
NAPROPAMIDE	79195	n/a	--	ug/L
NEBURON	38522	n/a	--	ug/L
NEGATIVE BASE/NEUTRAL & ACID ANALYSIS	B-NEG	n/a	--	
NEGATIVE PURGEABLE ORGANIC ANALYSIS	P-NEG	n/a	--	
NEGATIVE TRIHALOMETHANES (501.1,501.2,&501.3)	THMN	n/a	--	ug/L
NICKEL	01067	100	10	ug/L
NITRATE (AS NO3)	71850	45	2	mg/L

Chemicals and Parameters in California Drinking Water Quality Database
December 19, 2007

STORET No. = US EPA STORET number for chemical (A-XXX indicates the ID was assigned by CDPH in the absence of a STORET number)

MCL = Maximum Contaminant Level

DLR = Detection limit for purposes of reporting

Reporting units: ug/L = micrograms per liter; mg/L = milligrams per liter; pCi/l = picocuries per liter; MFL - million fibers per liter

NOTE: This list is intended to be used as a quick reference.

Refer to the chemical list and STORET numbers in Write-On for data submittal. [see <http://www.cdph.ca.gov/certlic/drinkingwater/Pages/EDTlibrary.a>]

Chemical / Parameter	STORET No.	MCL	DLR	Units
NITRATE + NITRITE (AS N)	A-029	10000	400	ug/L
NITRITE (AS N)	00620	1000	400	ug/L
NITRITE NITROGEN (NO2-N)	00615	n/a	--	ug/L
NITROBENZENE	34447	n/a	--	ug/L
NITROFEN	81303	n/a	--	ug/L
4-NITROPHENOL	34646	n/a	5	ug/L
NONADECANE (N)	77822	n/a	--	ug/L
NONYLPHENOL	77745	n/a	--	ug/L
NONYLPHENOL POLYETHOXYLATE	A-054	n/a	--	ug/L
NORTRON	45606	n/a	--	ug/L
1-NAPHTHOL	77441	n/a	--	ug/L
2-NITROPHENOL	34591	n/a	5	ug/L
OCTYLPHENOL	A-055	n/a	--	ug/L
OCTYLPHENOL POLYETHOXYLATE	A-056	n/a	--	ug/L
ODOR THRESHOLD @ 60 C	00086	3	1	TON
ORYZALIN	78884	n/a	10	ug/L
OVEX	39022	n/a	--	ug/L
OXAMYL	38865	50	20	ug/L
PARACHLOROMETA CRESOL	34453	n/a	--	ug/L
PARAQUAT	82416	n/a	20	ug/L
PARATHION	39540	n/a	0.02	ug/L
PCB-1016 (as decachlorobiphenyl, DCB)	34671	--	0.5	ug/L
PCB-1221 (as DCB)	39488	--	0.5	ug/L
PCB-1232 (as DCB)	39492	--	0.5	ug/L
PCB-1242 (as DCB)	39496	--	0.5	ug/L
PCB-1248 (as DCB)	39500	--	0.5	ug/L
PCB-1254 (as DCB)	39504	--	0.5	ug/L
PCB-1260 (as DCB)	39508	--	0.5	ug/L
PCBs-TOTAL (POLYCHLORINATED BIPHENYLS)(as DCB)	39516	0.5	0.5	ug/L
PCNB	39029	n/a	0.1	ug/L
PENOXALIN	82410	n/a	--	ug/L
2,2',4,4',5-PENTABROMODIPHENYL ETHER	A-085	n/a	--	ug/L
2,2',4,4',6-PENTABROMODIPHENYL ETHER	A-088	n/a	--	ug/L
PENTACHLOROENZENE	77793	n/a	--	ug/L
PENTACHLOROETHANE	81501	n/a	--	ug/L
PENTACHLOROPHENOL	39032	1	0.2	ug/L
PERCHLORATE	A-031	6	4	ug/L
cis-PERMETHRIN	82418	n/a	--	ug/L
trans-PERMETHRIN	82420	n/a	--	ug/L
PERMETHRIN	79191	n/a	--	ug/L
PERTHANE	39034	n/a	--	ug/L
pH, FIELD	00400	n/a	--	
pH, LABORATORY	00403	n/a	--	
PHENANTHRENE	34461	n/a	5	ug/L
PHENOL	34694	n/a	5	ug/L
1-PHENYLPROPANE (N-PROPYLBENZENE)	77224	n/a	0.5	ug/L
PHORATE	38870	n/a	0.2	ug/L
PHOSALONE	81291	n/a	--	ug/L
PHOSDIN	39610	n/a	--	ug/L
PHOSPHAMIDON	78881	n/a	--	ug/L
PHOSPHATE, TOTAL	00650	n/a	--	mg/L
PHOSPHATE, ORTHO-	00660	n/a	--	mg/L

Chemicals and Parameters in California Drinking Water Quality Database
December 19, 2007

STORET No. = US EPA STORET number for chemical (A-XXX indicates the ID was assigned by CDPH in the absence of a STORET number)

MCL = Maximum Contaminant Level

DLR = Detection limit for purposes of reporting

Reporting units: ug/L = micrograms per liter; mg/L = milligrams per liter; pCi/l = picocuries per liter; MFL - million fibers per liter

NOTE: This list is intended to be used as a quick reference.

Refer to the chemical list and STORET numbers in Write-On for data submittal. [see <http://www.cdph.ca.gov/certlic/drinkingwater/Pages/EDTlibrary.a>]

Chemical / Parameter	STORET No.	MCL	DLR	Units
PHOSTOXIN	998-A	n/a	--	ug/L
PICLORAM	39720	500	1	ug/L
POLYBROMINATED DIPHENYL ETHERS	A-057	n/a	--	ug/L
POLYCHLORINATED BIPHENYLS, TOTAL PCBs	39516	0.5	0.5	ug/L
POTASSIUM	00937	n/a	--	mg/L
PROFLURALIN	38872	n/a	--	ug/L
PROMETON	39056	n/a	--	ug/L
PROMETRYN	39057	n/a	2	ug/L
PROPACHLOR	38533	n/a	0.5	ug/L
PROPAMIDE	39080	n/a	--	ug/L
PROPANE	82358	n/a	--	ug/L
PROPANIL	39037	n/a	--	ug/L
PROPARGITE	82065	n/a	--	mg/L
PROPAZINE	39024	n/a	--	ug/L
PROPHAM	39052	n/a	--	ug/L
PROPOXUR	38537	n/a	--	ug/L
N-PROPYLBENZENE (1-PHENYLPROPANE)	77224	n/a	0.5	ug/L
PYRAMIN	45609	n/a	--	ug/L
PYRENE	34469	n/a	5	ug/L
PYRETHRINS	39930	n/a	--	ug/L
RADIUM 226	09501	--	1	pCi/L
RADIUM 226 COUNTING ERROR (CE)	09502	n/a	--	pCi/L
RADIUM 226 MDA95	A-074	n/a	--	pCi/L
RADIUM 228	11501	--	1	pCi/L
RADIUM 228 COUNTING ERROR	11502	n/a	--	pCi/L
RADIUM 228 MDA95	A-075	n/a	--	pCi/L
RADIUM 226 + RADIUM 228, COMBINED	11503	5	--	pCi/L
RADIUM 226 + RADIUM 228 COUNTING ERROR, COMBINED	11504	n/a	--	pCi/L
RADIUM 226 + RADIUM 228 MDA95	A-076	n/a	--	pCi/L
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	n/a	--	pCi/L
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	n/a	--	pCi/L
RA-226 OR TOTAL RA BY 903.0 MDA95	A-082	n/a	--	pCi/L
RADON 222	82303	n/a	100	pCi/L
RADON 222 COUNTING ERROR	82302	n/a	--	pCi/L
RDX (HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE)	81364	n/a	--	ug/L
RONNEL	39357	n/a	--	ug/L
ROUND-UP	39941	n/a	--	ug/L
SALICYLIC ACID	77403	n/a	--	ug/L
SECBUMETON	38542	n/a	--	ug/L
SELENIUM	01147	50	5	ug/L
SIDURON	38548	n/a	--	ug/L
SILICA	00955	n/a	--	mg/L
SILVER	01077	100	10	ug/L
SIMAZINE	39055	4	1	ug/L
SIMETRYN	39054	n/a	--	ug/L
SODIUM	00929	n/a	--	mg/L
SODIUM ABSORPTION RATIO	00931	n/a	--	
SODIUM CHLORATE	00726	n/a	--	ug/L
SOURCE TEMPERATURE C	00010	n/a	--	C
SPECIFIC CONDUCTANCE	00095	2200	--	US
STIROFOS	38877	n/a	--	ug/L
STRONTIUM-90	13501	8	2	pCi/L

Chemicals and Parameters in California Drinking Water Quality Database
December 19, 2007

STORET No. = US EPA STORET number for chemical (A-XXX indicates the ID was assigned by CDPH in the absence of a STORET number)

MCL = Maximum Contaminant Level

DLR = Detection limit for purposes of reporting

Reporting units: ug/L = micrograms per liter; mg/L = milligrams per liter; pCi/l = picocuries per liter; MFL - million fibers per liter

NOTE: This list is intended to be used as a quick reference.

Refer to the chemical list and STORET numbers in Write-On for data submittal. [see <http://www.cdph.ca.gov/certlic/drinkingwater/Pages/EDTlibrary.a>]

Chemical / Parameter	STORET No.	MCL	DLR	Units
STRONTIUM-90 COUNTING ERROR	13502	n/a	--	pCi/L
STRONTIUM-90 MDA95	A-078	n/a	--	pCi/L
STYRENE	77128	100	0.5	ug/L
SULFATE	00945	600	0.5	mg/L
SULFIDE	00745	n/a	--	mg/L
SULFOMETURON METHYL	A-005	n/a	--	ug/L
SWEP	38555	n/a	--	ug/L
2,4,5-T	39740	n/a	--	ug/L
2,3,7,8-TCDD (DIOXIN)	34676	30	5	pg/L
TEBUTHIURON	45607	n/a	--	ug/L
TEDION	39808	n/a	--	ug/L
TEPP	39620	n/a	--	ug/L
TERBACIL	38882	n/a	--	ug/L
TERBUFOS	82088	n/a	--	ug/L
TERBUFOS SULFONE	45612	n/a	--	ug/L
TERBUTHYLAZINE	38559	n/a	--	ug/L
TERBUTRYN	38887	n/a	--	ug/L
TERT-AMYL-METHYL ETHER	A-034	n/a	3	ug/L
TERT-BUTYL ALCOHOL	77035	n/a	2	ug/L
TERT-BUTYL FORMATE	A-047	n/a	--	ug/L
2,2',4,4'-TETRABROMODIPHENYL ETHER	A-084	n/a	--	ug/L
1,1,1,2-TETRACHLORETHANE	77562	n/a	0.5	ug/L
1,1,2,2-TETRACHLOROETHANE	34516	1	0.5	ug/L
TETRACHLOROETHYLENE	34475	5	0.5	ug/L
TETRACHLOROPHENOL	81849	n/a	--	ug/L
THALLIUM	01059	2	1	ug/L
THIOBENCARB	A-001	70	1	ug/L
2,4,5-TP (SILVEX)	39045	50	1	ug/L
TOLUENE	34010	150	0.5	ug/L
TOPSIN-MR	78880	n/a	--	ug/L
TOTAL DISSOLVED SOLIDS	70300	1500	--	mg/L
TOTAL ORGANIC CARBON (TOC)	00680	n/a	0.30	mg/L
TOTAL TRIHALOMETHANES (TTHM, THMs)	82080	80	--	ug/L
TOXAPHENE	39400	3	1	ug/L
TRIADIMEFON	38892	n/a	--	ug/L
TRIBROMOACETIC ACID (TBAA)	A-043	n/a	4	ug/L
S,S,S-TRIBUTYLPHOSPHOROTRITHIOATE	39040	n/a	--	ug/L
TRICHLOROACETIC ACID (TCAA) (one of the HAA5)	82723	--	1.0	ug/L
1,2,3-TRICHLOROBENZENE	77613	n/a	0.5	ug/L
1,2,4-TRICHLOROBENZENE	34551	5	0.5	ug/L
1,3,5-TRICHLOROBENZENE	77614	n/a	--	ug/L
1,1,1-TRICHLOROETHANE	34506	200	0.5	ug/L
1,1,2-TRICHLOROETHANE	34511	5	0.5	ug/L
TRICHLOROETHYLENE	39180	5	0.5	ug/L
TRICHLOROFLUOROMETHANE	34488	150	5	ug/L
TRICHLORONATE	38897	n/a	--	ug/L
2,4,6-TRICHLOROPHENOL	34621	n/a	5	ug/L
1,2,3-TRICHLOROPROPANE	77443	n/a	0.005	ug/L
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	1200	10	ug/L
TRICLOSAN	A-069	n/a	--	ug/L
TRIFLURALIN	81284	n/a	--	ug/L
TRIHALOMETHANES (THMs) - TOTAL	82080	80	0.5	ug/L

Chemicals and Parameters in California Drinking Water Quality Database
December 19, 2007

STORET No. = US EPA STORET number for chemical (A-XXX indicates the ID was assigned by CDPH in the absence of a STORET number)

MCL = Maximum Contaminant Level

DLR = Detection limit for purposes of reporting

Reporting units: ug/L = micrograms per liter; mg/L = milligrams per liter; pCi/l = picocuries per liter; MFL - million fibers per liter

NOTE: This list is intended to be used as a quick reference.

Refer to the chemical list and STORET numbers in Write-On for data submittal. [see <http://www.cdph.ca.gov/certlic/drinkingwater/Pages/EDTlibrary.a>]

Chemical / Parameter	STORET No.	MCL	DLR	Units
1,2,3-TRIMETHYLBENZENE	77221	n/a	--	ug/L
1,2,4-TRIMETHYLBENZENE	77222	n/a	0.5	ug/L
1,3,5-TRIMETHYLBENZENE	77226	n/a	0.5	ug/L
TRIMETHYL BENZENE	78136	n/a	0.5	ug/L
2,4,6-TRINITROTOLUENE (TNT)	81360	n/a	--	ug/L
TRITIUM	07000	20000	1000	pCi/L
TRITIUM COUNTING ERROR	07001	n/a	--	pCi/L
TRITIUM MDA95	A-079	n/a	--	pCi/L
TURBIDITY, FIELD	82078	5	0.1	NTU
TURBIDITY, LABORATORY	82079	5	--	NTU
URANIUM by mass method	28011	--	1	ug/L
URANIUM by radioactivity method	28012	20	1	pCi/L
URANIUM COUNTING ERROR	A-028	n/a	--	pCi/L
URANIUM MDA95	A-073	n/a	--	pCi/L
VANADIUM	01087	n/a	3	ug/L
VENDEX	A-003	n/a	--	ug/L
VERNOLATE	82200	n/a	--	ug/L
VINYL ACETATE	77057	n/a	--	ug/L
VINYL CHLORIDE	39175	0.5	0.5	ug/L
m-XYLENE	81710	--	0.5	ug/L
o-XYLENE	77135	--	0.5	ug/L
p-XYLENE	78132	--	0.5	ug/L
m,p-XYLENE	A-014	--	0.5	ug/L
XYLENES (TOTAL)	81551	1750	--	ug/L
ZINC	01092	5000	50	ug/L
ZINEB	38912	n/a	--	ug/L
ZIRAM	38917	n/a	3	ug/L
ZYTRON	81285	n/a	--	ug/L

spx]

spx]

spx]

NOTE: Chromium for hex chrome screen (A-044) was to be used ONLY for the unregulated chemical monitoring requirement (UCMR) for hexavalent chromium. All UCMR monitoring for hexavalent chromium and use of the chromium screen were to have been completed by Dec. 31, 2002.

spx]

spx]

NOTE: Use STORET 00951 for natural fluoride in the drinking water source only.
NOTE: Use STORET A-035 for fluoride-treated water in the distribution system only.
Systems that do not provide fluoride treatment should not use A-035.

MDA95 is Minimum Detectable Activity at the 95% confidence level (see 22 CCR 64442 & 64443)

spx]

MCL is 4 millirem/yr to total body or any internal organ (see 22 CCR 64443)

spx]

spx]

spx]

MDA95 is Minimum Detectable Activity at the 95% confidence level (see 22 CCR 64442 & 64443)

spx]

MDA95 is Minimum Detectable Activity at the 95% confidence level (see 22 CCR 64442 & 64443)

Units are picograms per liter.

spx]

MDA95 is Minimum Detectable Activity at the 95% confidence level (see 22 CCR 64442 & 64443)

NOTE: Uranium measurement using a mass method (DLR = 1 ug/L) is converted to activity (pCi/L) by multiplying the mass measurement (ug/L) by a 0.67 conversion factor.

MDA95 is Minimum Detectable Activity at the 95% confidence level (see 22 CCR 64442 & 64443)